



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C/26
7/5
आज़ादी का
अमृत महोत्सव


No.F6/DFS/MS/EH/NDZ/2026/395

Dated: 24/04/2026

FIRE SAFETY CERTIFICATE

Certified that the Preet Vihar Official (A Unit of Flyleaf Hospitality LLP) is running on 1st floor of the building which is comprised of Basement + Ground + 03 upper floors located at C-50 Preet Vihar, Vikas Marg, Delhi-110092 & was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/NDZ/2023/263 dated 22/08/2023. The Restaurant was re-inspected by officer concerned of this department on 13/04/2026 in the presence of Mr. Nitish (Manager) and found that the building/premises has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. The building/premises is fit for occupancy of Group D "Assembly Building" (Eating House /Restaurant at 1st floor only) with effect from. 24/04/2026.....and valid upto 31.03.2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on24/04/2026.....at New Delhi by


24/4/26
(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Reference: etl.mcdonline application no. 2026033103926.

Conditions for the validity of Fire Safety Certificate

1. This Fire Safety Certificate is valid for Restaurant at 1st floor only.
2. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
3. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
4. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
5. The trained fire fighting staff should be available round the clock.
6. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
10. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

1.	Name and address of the building:	M/s Preet Vihar Official (A Unit of Flyleaf Hospitality LLP) located C-50 Preet Vihar, Vikas Marg, Delhi-110092.			
2.	Building is comprised of	Basement + Ground + 03 upper floors (Restaurant running at 1 st floor of the building)			
3.	Type of occupancy	Group D - Assembly (Restaurant)			
4.	Type of case:	Renewal			
5.	Details of previous FSC:	F6/DFS/MS/EH/NDZ/2023/263 dated 22/08/2023			
6.	Fire safety directives no.:	NBC Part-IV-2016			
7.	Date of inspection:	13.04.2026			
8.	Name of the inspecting officer:	Rajesh Kumar Shukla, ADO (L.N)			
9.	Name and designation of the officer from the building side:	Mr. Nitish (Manager)			
10.	Year of construction:	2022			
11.	Reference letter no.:	etl.mcdonline application no. 2026033103926			
S.No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements as per Rule 35(6), DFS Rule 2010	Provide at site	Remarks MR/NMR	
1	Access to Building:				
	A	Road width	6.0 m	30 m	MR
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits:				
	A	No. of Staircase:			
		a) Upper floors	2 nos.	3 nos.	MR
		b) Basements	NA	NA	NA
	B	Width of the Staircase			
		a) Upper floors	1.50 m	1.50 m x 2 & 1.15 m	MR
		b) Basements	NA	NA	NA
	C	Protection of Exits			
		a) Fire check door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace	1 no.	1 no.	MR
	E	Width of the corridor	NA	NA	NA
	F	Door size/exits	1.5 m x 2 nos.	1.50 m x 2 nos. & 1.0 m	MR
3	Compartmentation:				
	A	Fire check doors	NA	NA	NA
	B	Sealing of horizontal & vertical opening	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Basements	NA	NA	NA
	B	Upper floors	NA	NA	NA
5	Fire Extinguishers:				
	A	Total numbers	02 nos.	04 nos.	MR
	B	Types	ABC +CO ₂	ABC +CO ₂	MR
	C	ISI marking	ISI marked	ISI marked	MR
6	First Aid Hose Reel:				
	A	Total no. at each floor	01 no.	01 no.	MR
	B	Length of hose reel	30 m	30 m	MR
	C	Nozzle diameter	5 mm	5 mm	MR

De

7	Automatic Fire Detection and Alarm System (ADAS):			
	A	Type of detectors	NA	NA
	B	Location of main panel	NA	NA
	C	Location of repeater panel	NA	NA
	D	Alternate power source	NA	NA
	E	Hooter's location	NA	NA
8	MOEFA:			
9	Public Address System:		Required	Provided
10	Automatic Sprinkler System:		NA	NA
	A	Basement		
	B	Upper floor	NA	NA
	C	Sprinklers above false ceiling	NA	NA
11	Internal Hydrants:			
	A	Size of down comer	100 mm	100 mm
	B	No. of hydrants per floor	01 no.	01 no.
	C	Hose box	01 no.	01 no.
12	Yard Hydrants:			
	A	Total no. of hydrants	NA	NA
	B	Hose box	NA	NA
13	Pumping arrangements: System provided & maintained by building management- The available system is of higher category and capacity			
	A	Ground Level		
		a) Discharge & head of main pump	NA	2280 LPM & 60 m
		b) Number of main pump	NA	01 no.
		c) Discharge & head of jockey pump	NA	180 LPM & 60 m
		d) Discharge & head of standby pump	NA	2280 LPM & 60 m
		e) Auto starting/ manual stopping	NA	Provided
	B	Terrace Level		
		a) Discharge of terrace pump	450 LPM	450 LPM
		b) Head of terrace pump	40 m	40 m
		c) Alternate power supply	Required	Provided
		d) Auto starting of pump	Auto	Provided
14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	NA	NA
	B	Draw off connection	NA	NA
	C	Fire service inlet	NA	NA
	E	Access to tank	Required	Provided
	D	Overhead tank capacity	20,000 ltrs	10,000 ltrs + 1,00,000 ltrs UG tank provided
15	Exit Signage:		Required	Provided
16	Provision of lift:		Required	Provided
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Fireman switch	NA	NA
	E	Lift signage	NA	NA
17	Standby Power Supply:		Required	Provided
18	Refuge Area:			
	A	location	NA	NA
	B	Total area	NA	NA
19	Fire Control Room:			
	A	Fire detection system panel	NA	NA
	B	Flow switch panel	NA	NA
	C	P a system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plan	NA	NA

2/10

M/s Preet Vihar Official (A Unit of Flyleaf Hospitality LLP) located C-25 Preet Vihar, Vikas Marg, Delhi-110092.

20	Special Fire Protection for special risk if any	
A	Special Fire Protection system for Protection of Special Risk, if any:	NA

LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Not Provided (NP) Provide but Not Functional (PNF).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2023/263 dated 22/08/2023 is **recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.**


Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (L.N)

DO (East)  15/4/26

CFO (NDZ)

 20/4/26

Principal Director

CFO to Secy.

CFO (NDZ)


 21/4/26

 22/4/26

ADO/KN

FI is put up, as approved

CFO (NDZ)

 23/4/26

 24/4/26

ms
Up loaded
24/04/26