

C/35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No.F.6/DFS/MS/Hospital/2025/NDZ/ 606

Dated: 09/12/2025

To,

The Director
Pentagram Hospital Pvt. Ltd.,
F-1, Kh. No. 94/2 & 95 Khajoori Khas Colony,
Main Wazirabad Road,
Delhi-110094

Subject: -Regarding issuance of Fire Safety Certificate in r/o Pentagram Hospital Pvt. Ltd., F-1, Kh. No. 94/2 & 95 Khajoori Khas Colony, Main Wazirabad Road, Delhi-110094.

Sir,

With reference to your Outdoor diary No. 6271 dated 22/09/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 17/11/2025 in the presence of Dr. Rahul Chaudhary (Director). The hospital building comprised of basement, ground plus three upper floors. During the course of inspection following observations were made: -

1. Two staircases of 02-meter width are to be provided from the basement to the third floor.
2. A corridor of 1.80 meters width is provided against the required 2.40 meters.
3. Pressurization of lift shaft required but not provided.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier, The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


8/12/25

(Dr. S. K. TOMAR)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE