



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/2025/Hospital/ 27

Dated 15/01/2025

To
 Dr. Rajesh Gupta,
 Pentamed Hospital at 7, Local Shopping Centre,
 Derawal Nagar, Gujrawala Town, Phase-IV,
 Delhi-110009.

Sub: Regarding renewal of fire safety certificate r/o Pentamed Hospital located at 7, Local Shopping Centre, Derawal Nagar, Gujrawala Town, Phase-IV, Delhi-110009

Please refer letter to letter No- nil dated 02.01.2024 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 09.01.2025 to check the existing fire safety measures. During inspection it has been observed that the hospital premise is comprised of basement, ground & 03 upper floors. At the time of inspection Sh. Deepak Sethi (Manager) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire check doors found removed at some places.
2. Smoke management system provided in the basement but found not functional.
3. One inspection ladder is required for fire water tank on terrace level.
4. One room & one kitchen temporary shed on third floor terrace level area which needs to be removed.
5. One electrical panel installed on terrace floor and covered by fiber sheet it's a highly flammable and needs to be replace by non- flammable sheets.

Keeping in view of above shortcomings, the said building is not safe from fire safety point of view & renewal of Fire Safety Certificate cannot be considered at this stage. Hence, you are advised to comply all the shortcomings at the earliest under intimation to this department. Any loss of life and property untoward mishap due to non- compliance of the fire safety measures in the event of fire and other emergency the management is solely responsible.

Yours faithfully

(Atul Garg)
 Director

Ph:-011-23414000

Copy to:-

1. The Medical Superintendent Nursing Home at 3rd floor, DGD building, S-1, School Block, Shakarpur, Delhi-110092.