



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/WZ/2025/ 497

Dated:- 18/09/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Petroleum Oil Storage Tank Terminals (Indian Oil Corporation Ltd.) at Village Tikri Kalan, Ghevra More, Delhi-110041, owned/occupied by Indian Oil Corporation Ltd., was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/2014/2031 Dated 28/08/2014. The said premise was re-inspected by the officer concerned of this department on 21/08/2025 in the presence of Sh. Parveen Kumar (Chief Terminal Manager) & Sh. Rishabh Gupta (Safety Officer) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and provision of OISD 117 (Revised) and that the premises/building is fit for occupancy class "Hazardous Building" Group - J with effect from 18/09/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 18/09/2025 at New Delhi by.

  
Virendra Singh  
Chief Fire Officer

Copy to: -

1. The Chief Terminal Manager, Indian Oil Corporation Limited, Delhi Terminal, Tikri Kalan, Ghevra Mode, Rohtak Road, Delhi-110041.

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of authorized construction or alteration (Clause of 1.4.3 of UBBL-2016), if any.
6. Work under procurement/installation mentioned in the undertaking shall be complied before the commencement of the plant. The same shall be get inspected from OISD under intimation to this department.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

2/1/22

Submitted as per report dated 8/9/2025 of  
ADO & Dy CFO (W2) on basis of OISD-117, please

Principal Director ~~\_\_\_\_\_~~ 11 Aug  
9/9/2025  
CFO to Secm.  
12/9/25

CFO  
Dy CFO (W2)  
~~ADO~~ 11 Aug  
15/9/2025

dy  
16/9

sig, ADO (JWP)  
F.f. letter is put-up for your signature 1st.

CFO 11 Aug  
17/9/2025

11/11/25  
16/09/25  
ADO (JWP)

MS