



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



cl/209

No. F.6/DFS/MS/Assy/2025/SZ/ 401

Dated: 01/08/2025

FIRE SAFETY CERTIFICATE

Certified that the building of **Phase 3A-Terminal Building Zone 28** at Terminal-I, IGI Airport, New Delhi-110037, comprised of Ground + Mezzanine + First floor (Food Court at First Floor), owned/occupied by Delhi International Airport Limited, was issued FSC by this department vide letter No. F.6/DFS/MS/Assembly/2022/SZ/299 dated 06/07/2022. The premise was re-inspected by the officer concerned of this department on 09/07/2025 in the presence of Sh. Rakesh Kumar (Head-FP&S) and found that the said building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy class "**Assembly, Group D**" (Food Court at First floor) with effect from 01/08/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/08/2025 at New Delhi by


30/7/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Sh. Rakesh Kumar, Head Fire Prevention & Safety, Delhi International Airport Limited, IGI Airport, New Delhi-110037

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1.	Name & address of the building	Phase 3A-Terminal Building Zone 28 at Terminal-1, IGI Airport, New Delhi-110037		
2.	Type of Occupancy	Assembly (Food Court on First floor only)		
3.	Building Comprised of	Ground + Mezzanine + First floor.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/Assembly/2022/SZ/299 Dt. 06/07/2022		
6.	Fire Safety directives Letter No.	F.6/DFS/MS/2020/BP/237 dated 02/11/2020		
7.	Date of inspection	09/07/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. Rakesh Kumar (Head-FP&S)		
10.	Year of Construction	2022		
11.	Applicant's letter No	DIAL/ARFF/01/2025-26/12 dated 03/07/2025 Outdoor Diary No. 3371 dated 04/07/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	09 mtr	MR
	• Gate width	06 mtr	06 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos	02 Nos	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50m (each)	1.50m (each)	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	02 Nos	Provided	MR
	e. Width of Corridor	2 mtr	3 mtr	MR
	f. Door Size	1.5 mtr	1.5 mtr	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	16 Nos	20 Nos	MR
	• Types	ABC/CO ₂ /W.CO ₂	Provided	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02 Nos	01 no in area & 01 in adjoining area	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 mm	5 mm	MR

SP

N-55

7.	Automatic fire detection and alarming system.			
	• Type of detector	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Required	Fire Control Room	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	150 mm	150 mm	MR
	• Number of hydrants per floor	02 Nos	02 Nos	MR
	• Hose Box	02 Nos	02 Nos	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	02 Nos	MR
	• Hose Box	Required	02 Nos	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	Hyd: 4730 LPM Sprk: 3785 LPM	Hyd: 4730 LPM Sprk: 3785 LPM	MR
	➤ Head of main pump	105m & 75m	Provided	MR
	➤ Number of main pumps	02 Nos	Provided	MR
	➤ Jockey pump out put	473 & 378 LPM	Provided	MR
	➤ Jockey pump head	112m & 84m	Provided	MR
	➤ Standby Pump out put	Hyd: 4730 LPM Sprk: 3785 LPM	Hyd: 4730 LPM Sprk: 3785 LPM	MR
	➤ Standby Pump Head	105m & 75m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	5,00,000 lts	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A


N-56

19.	Fire Control Room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of Special Risks, if any;			N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules, the fire safety certificate issued vide this department letter No. F.6/DFS/MS/Assembly/2022/SZ/299 dated 06/07/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (SJ)

DO (SD)

CO

11/11/2025

Principal Director

CO to Gen.

CO

22/07/22

11/11/2025

ADO (SJ)

11/11/2025

P.T.O