



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2025/NDZ/ 25

Dated: 25/07/2025

**FIRE SAFETY CERTIFICATE**

Certified that "Physicswallah Limited" located at Plot No. 12, Gagan Vihar, Delhi-110051, building comprised of Basement (Other Party), Stilt (Parking), Upper Ground & Three Upper Floors (Coaching Centre) owned / occupied by Physicswallah Limited have complied with the fire prevention and Fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 05/07/2025 in presence of Mr. Anupam Singh and that the building / premises is fit for occupancy class "Educational" (Group-B) for Upper Ground & Three upper floors only with effect from 25/07/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Subject to conditions printed below

Issued on 25/07/2025 at New Delhi by.

25/07/2025  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER

**Copy to:-**

1. The Commissioner, Municipal Corporation of Delhi, 419 Udtog Sadan, Patparganj, Industrial Area, Delhi-110092 (w.r.t. online ID-70000126 Dated 09/06/2025)
2. Mr. Naveen, Physicswallah Limited, Plot No. 12, Gagan Vihar, Delhi-110051.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

## INSPECTION REPORT

1. Name & address of the building: Physicswallah Limited, Plot No. 12, Gagan Vihar, Delhi-110051.
2. Type of Occupancy : Educational, Group-B(Coaching Centre)
3. Building comprised of : Basement (Other Party), Stilt (Parking), Upper Ground & Three Upper Floors (Coaching Centre)
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives Letter No. : NBC (Part-IV)
7. Date of inspection : 05/07/2025
8. Name of the Inspecting Officer: R.K. Sinha, A.D.O (Bawana)& A.K. Jaiswal, D.O. (East)
9. Name and designation of Officer from the building side : Mr. Anupam Singh
10. Year of Construction : 2024
11. Applicant's online no. : 70000126 Dated 09/06/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC /UBBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 M	Provided	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	2	MR
	e. Width Of Corridor	1.50m	Provided	MR
	f. Door Size	1.00m	1.20m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	12	20	M/R
	• Types	ISI marked	Provided	M/R
	• IS marking	Required	Provided	M/R



~ 3

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100mm	Provided	MR
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM x 2	MR
	➤ Head of the pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	15,000 Ltr.	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

**Note:- Basement is not checked as it is in possession of other party. Entry of Basement is sealed by brick wall. Lift entering in basement is also compartmented (Sealed) by brick wall in basement. Photograph & Undertaking attached.**

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
 Name : Rajiv Kumar Sinha  
 Designation : A.D.O. (Bawana)

Signature of the Inspecting Office  
 Name : Ashok Kumar Jaiswal  
 Designation : D.O. (East Division)

Dy. C.F.O. (N.B.Z.)

C.F.O.

11/07/2025

10/07/25

Director

11/07/25

D.O. (N.B.Z.)