



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/EH/2025/SZ/ 203

Dated: 09/05/2025

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, P.S. Defense Colony  
New Delhi-110049

**Sub: Inspection report in r/o M/s Pinch of Spice (A unit of MNC Hospitalities Mocktails N Cocktails LLP) situated at 3<sup>rd</sup> Floor, Plot No. 18, Wadhwa Plaza-III, Central Market, Sector-10, Dwarka, New Delhi-110075**

Sir,

Please refer to online portal (etl.mcdonline.nic.in) Id. **2025042407152** dated 24/04/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 03/05/2025 in the presence of Sh. Vikram Pratap of the eating house and the shortcomings observed are as below.

1. First aid hose-reel provided but non-functional.
2. Terrace level fire pumps found removed.
3. Overhead water tank exclusively for firefighting capacity 9,000 liters provided against required 10,000 ltrs also used for domestic purposes.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premise in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(APUL GARG)  
DIRECTOR

Ph. 011-23414000

Copy to: -

1. Sh. Jitender Mohan, M/s Pinch of Spice (A unit of MNC Hospitalities Mocktails N Cocktails LLP) situated at 3<sup>rd</sup> Floor, Plot No. 18, Wadhwa Plaza-III, Central Market, Sector-10, Dwarka, New Delhi-110075