



75  
Azadi Ka  
Amrit Mahotsav

C/V4

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/EH/2025/NDZ/ 255

Dated: 09 / 06 / 2025

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, P.S. Defense Colony  
New Delhi-110049

**Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Pizza Hut (A unit of Devayani International Ltd) located at Ground Floor, Devika Sadar Bazar, Old Tanga Stand, Qutub Road, Delhi-110006**

Sir,

Please refer to online portal ID No. **2025051408432** dated **14/05/2025**, on the subject cited above. In this connection, it is to inform you that the premise was re-visited by the officer concerned of this department on dated 27/05/2025 with a view to verify compliance of shortcomings issued vide this office letter No. F.6/DFS/MS/EH/NDZ/2024/82 dated 27/02/2024, but the eating establishment was found closed. Mr. Sagar Mathur (Guard) was present at the time of visit.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety arrangements/ certificate shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)

DIRECTOR

T. No. 011-23414000

09/06/25

Copy to: -

1. Sh. Abhishek Mittal, M/s Pizza Hut (A unit of Devayani International Ltd) located at Ground Floor, Devika Sadar Bazar, Old Tanga Stand, Qutub Road, Delhi-110006

C-6

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No F6/DFS/MS/EH/NDZ/2024/ 82

Dated: 27/02 /2024

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** - Regarding renewal of Fire Safety Certificate in r/o **M/s Pizza Hut** (A unit of M/s Devyani International Ltd.) located at **Qutab Road, Sadar Bazar, Delhi - 06.**

Sir,

This has reference to online application ID No. 2024012000644 dated 08.02.2024 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 21.02.2024 in presence of Mr. Sahel (RGM) and it was observed that building is comprised of 02 Basement + Ground + 04 upper floors (but restaurant at ground floor only). During inspection, following shortcomings were observed:

1. 02 nos. of doors are provided having width of 1.20 m & 0.80 m respectively against the requirement of 1.5 m each.
2. First aid hose reel not provided.
3. Overhead water storage tank provided 10,000 liters against the requirement of 20,000 liters.
4. Plan of the restaurant duly signed by architect and owner/ occupier.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service  
Tel: 01123414000  
d/c  
26/2

**Copy to:-**

The Manager,  
M/s Pizza Hut (A unit of Devyani International Ltd.), Qutab Road, Sadar Bazar, Delhi - 06.