GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/NDZ/2025/ 238

Dated: 3010512025

Yours faithfully

To,

The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. addlcp.lic-dl@nic.in

Sub:

Regarding issuance of fire safety certificate in respect of Pizza Hut (A unit of M/s Devyani International Ltd.), located at Shop No.G-02, Ground Floor, Infinity S.K. Mall, Karkardooma Metro Station, Delhi-110092.

Sir,

Please refer to your online application no. 2025050607968 dated 06/05/2025, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 19/05/2025 in the presence of Sh. Abhishek Mittal to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant is running at Ground Floor only in a building comprised of Basement + Ground + 02 Upper Floors. Fire safety arrangements such as Fire Extinguishers, MOEFA etc provided. However the following shortcomings were observed.

- 1. There are two exits door 2 X 1.20 m against the required of 1.50 mtr each.
- 2. Smoke Management System are not provided.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Copy to: -

1. The Dy. Health Officer, MCD, Public Health Department, South Zone, Green Park, Delhi-110016.

 The Owner/Occupier, Pizza Hut (A unit of M/s Devyani International Ltd.), located at Shop No.G-02, Ground Floor, Infinity S.K. Mall, Karkardooma Metro Station, Delhi-110092.