

C/70

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2025/ 77

Dated: 11 /02 /2025

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of M/s P. K. International at 9186/4, 9220/5, Multani Dhanda, Pahar Ganj, New Delhi.

Sir,

This has reference to online application I.D. No. 2025012701071 dated 27.01.2025 on the subject cited above. In this connection, it is to inform you that guest house was visited by the officer concerned of this department on 04.02.2025 in the presence Manager and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. Fire extinguishers provided but non functional.
2. First aid hose reel provided but not functional.
3. CO detectors with panel and alarm system provided but not functional.
4. Fire pump not in auto start mode.
5. Occupancy above third floor is not permitted as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

**Copy to:-**

The Manager,

M/s P. K. International at 9186/4, 9220/5, Multani Dhanda, Pahar Ganj, New Delhi.