



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/280

Dated: 25/03/2025

FIRE SAFETY CERTIFICATE

Certified that the PM Shri Kendriya Vidyalaya at Andrews Ganj, New Delhi-110024, having 03 blocks, comprised of – Sr. Sec. Blk - Ground + 02 Upper floors, Sec. Block- Ground + 02 Upper floors & Primary Block- Ground floor having 48 class rooms & 12 other rooms, owned/occupied by Kendriya Vidyalaya, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2022/SZ/17 dated 05/01/2022. The premise was re-inspected by the officer concerned of this department on dated 15/03/2025 in the presence of Sh. Raj Kumar Sharma (Principal) and observed that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Director of Education Circular No. F6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 and that the premise/building is fit for occupancy class "Educational Group B" (Sr. Sec. School) with effect from 25/03/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/03/2025 at New Delhi by

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. Principal, PM Shri Kendriya Vidyalaya located at Andrews Ganj, New Delhi-110024
2. Asst. Commissioner, Kendriya Vidyalaya Sangathan, Delhi Region, JNU Campus, New Mehrauli Road, New Delhi-110067

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
3. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1.	Name & address of the building	PM Shri Kendriya Vidyalaya located at Andrews Ganj, New Delhi-110024		
2.	Type of Occupancy	Educational Building Group-B (School)		
3.	Building Comprised of	Ground + Two Upper Floors.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/School/2022/SZ/17 Dt. 05/01/22		
6.	Fire Safety Directives Letter No.	DOE Cir. No. 3298 to 3398 Dt. 01/03/2011		
7.	Date of inspection	15/03/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. Raj Kumar Sharma (Principal)		
10.	Year of Construction	1968		
11.	Applicant's letter No.	F.69/K.V.A. Ganj/2024-25/1252 Dt. 01.03.25 received through ODD No.13073 Dt. 03.03.25		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	10 mtr	MR
	• Gate width	05 mtr	3nos of 5m each	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos	04 Nos	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.50m x 3nos & 1.30m x 1no.	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No of continuous staircase to terrace	01 No	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Managements System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers			
	• Total numbers	45 Nos	Provided	MR
	• Types	ABC/CO ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors.	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down- comer	-NA-	-NA-	-NA-
	• Number of hydrants per floor	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	-NA-	-NA-	-NA-
	➤ Head of main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Staring/Manual stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw of connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000 ltr	Provided	MR
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	➤ Pressurization of lift lobby	-NA-	-NA-	-NA-
	➤ Communication in lift Car	-NA-	-NA-	-NA-
	➤ Fireman's Grounding Switch	-NA-	-NA-	-NA-
	➤ Lift Signage	-NA-	-NA-	-NA-
17.	Standby Power Supply			
18.	Refuge Area			
	➤ Total area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-

N-25

19.	Fire Control Room			
	➤ Detector system panel	-NA-	-NA-	-NA-
	➤ Flow Switch Panel	-NA-	-NA-	-NA-
	➤ PA System Panel	-NA-	-NA-	-NA-
	➤ Battery backup	-NA-	-NA-	-NA-
	➤ Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	-NA-	-NA-	-NA-

The fire protection systems provided in the premises/building were test checked at random and found functional at the time of inspection. The shortcomings issued vide letter No. F.6/DFS/MS/School/2025/SZ/51 dated 22/01/2025 found complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2022/SZ/17 dated 05/01/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

Santosh Kumar
18.03.25
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

[Signature]
19/3/25

CFO (MS)

[Signature]
19/3/25

Director
[Signature]
19/3/25

ADY/S

Sir, F.T letter is put up for your sig pl

Director
[Signature]
21/03/25

Santosh Kumar
20/03/25