



Dated: 16/07/2025

No. F6/DFS/MS/School/NDZ/2025/912

FIRE SAFETY CERTIFICATE

Certified that the **Plato Public School** located at **I.P Extension, Patparganj, Delhi - 110092**, building comprised of Ground plus four upper floors (School running on Ground plus three floors only) and 4th floor (SPS) sealed by owner, owned/occupied by **Plato Public School** was issued FSC vide letter No. F6/DFS/MS/School/NDZ/2022/711 dated 27/06/2022. The school building was re-inspected by the officers concerned of this department on 05/07/2025 in presence of Ms. Sangeeta (HOS) and found that the said school building have deemed complied with the fire prevention and fire safety requirements provided in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class **Group - B "Educational Building" for ground plus three upper floors only** with effect from 16/07/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 16/07/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Commissioner, MCD, JLN Marg, Civic Centre, New Delhi-110002.
2. The Dy. Director of Education, D - Block, Anand Vihar, Delhi-110092.
3. The Principal, Plato Public School located at I.P Extension, Patparganj, Delhi - 110092.

Conditions for the validity of Fire Safety Certificate

1. **Fire Safety Certificate is valid for ground plus three upper floors only.**
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Plato Public School, located at I.P Extension, Patparganj, Delhi - 110092.		
2	Building is comprised of	Ground plus four upper floors (School running on G+3 floors only and 4 th floor (SPS) sealed by owner.		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2022/711 dated 27/06/2022		
6	Fire safety directives letter no.	D.O.E. Old Circular 2005		
7	Date of inspection	05/07/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, A.D.O / Laxmi Nagar & Ashok Kumar Jaiswal, Divisional Officer / East		
9	Name of the designation of officer from the building side	Ms. Sangeeta (HOS)		
10	Year of construction	2004-05		
11	Applicant's letter no.	Outdoor Dairy No: 2921 dated 20/06/2025		
S. No	Minimum standard of fire prevention and fire safety U/R 33	Requirement Circular	Provided at site	Remarks MR/NMR
1.	Access to Building:			
A	Road width	6.0 mtrs.	15 mtrs.	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	02 nos.	02 nos.	MR
	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.5 mtrs.	1.40 mtrs. X 2	MR (as accepted earlier)
	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no	02 nos	MR
E	Width of corridor	1.5 mtrs	1.7 mtrs	MR
F	Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	Required	Provided	MR
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4.	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

SPS : Semi Permanent structure.

WdA

5. Fire Extinguisher:				
A	Total numbers	12 nos.	16 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	Required	Provided	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	01 nos.	01 nos.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	N/A	N/A	N/A
9	Public Address System:	N/A	N/A	N/A
10 Automatic Sprinkler System:				
A	Basement	Required	Provided	MR
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	01 no.	01 no.	MR
C	Hose box	01 no.	01 no.	MR
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2 Terrace Level				
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	40 mtrs.	40 mtrs.	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

Plato Public School located at I.P Extension, Patparganj, Delhi - 110092.

14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	5,000 liters	10,000 liters	MR
15 Exit Signage:		Required	Provided	MR
16 Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17 Standby Power Supply:		N/A	N/A	N/A
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20 Special Fire Protection systems for protection of special Risks, if any:				

Note: - Building comprised of Ground plus four upper floors (School running on Ground plus three floors only) and 4th floor (SPS) sealed by owner (Undertaking enclosed).

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of FSC issued vide letter no. F6/DFS/MS/School/NDZ/2022/711 dated 27/06/2022, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer
Name: Yashwant Singh Meena
Designation: ADO /Laxmi Nagar

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation: Divisional Office/ East

Dy. C.F.O. 9/7/2025
C.F.O. 11/7/2025
Director 11/07/25
Sir, F.T. letter is sent for sign. Alesary
Director 14/7/2025