



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/BP/2025/ 356

Dated: 29 /07/2025

To,

The Executive Engineer -I (Bldg.)HQ,  
Municipal Corporation of Delhi,  
9<sup>th</sup> Floor, Civic Centre, Minto Road,  
New Delhi – 110002.

**Sub: Online building plan in r/o Plot No. 186, Block-C, Rewari Line Industrial Area, Mayapuri Phase-II, New Delhi - 110064.**

Sir,

Please refer your Online Request ID No. 20021848 dated 15-07-2025 on the subject cited above. In this connection this is to inform you that the online building plans have been examined by this department and observed following shortcomings:

1. Pump room is not segregated from the staircase landing.
2. Protection of Steel staircase is not proposed.

Therefore, plans are rejected.

Yours faithfully

  
29/7/2025  
(Virendra Singh)  
Chief Fire Officer  
Ph. 011 - 23413339

