



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

75
आज़ादी का
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/BP/2025/ 161

Dated: 16 /04/2025

To,

The Executive Engineer -I (Bldg.)HQ,
Municipal Corporation of Delhi,
9th Floor, Civic Centre, Minto Road,
New Delhi – 110002.

**Sub: Online building plan in r/o Plot No. 57, Block-B, Rewari Line Mayapuri,
Industrial Area, Phase-II, New Delhi - 110064.**

Sir,

Please refer your Request ID No. 20018924 dated 08-04-2025 on the subject cited above. In this connection it is to inform you that the online building plans have been examined by this department and observed following shortcomings:

1. The height of the building as mentioned in the section, is not matching with the terrace plan.
2. Smoke management system for basement is not proposed.
3. The IS specification number of sprinkler system is not in accordance with NBC-Part-4.

Therefore, plans are rejected.

Yours faithfully

(ATUL GARG)

DIRECTOR

Ph. 011-23414000

[Handwritten signature and initials]