



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/BP/2025/ 477

Dated: 26 /09/2025

To,

The Executive Engineer -I (Bldg.)HQ,
Municipal Corporation of Delhi,
9th Floor, Civic Centre, Minto Road,
New Delhi – 110002.

Sub: Online building plan in r/o Plot No. 13/1, Block-A, Rewari Line Industrial Area, Mayapuri Phase-I, New Delhi - 110064.

Sir,

Please refer your Online Request ID No. 10121015 dated 17-09-2025 on the subject cited above. In this connection this is to inform you that the online building plans have been examined by this department and observed following shortcomings:

1. Information, as filled in CAF are not in accordance with NBC-Part-4, 2016 and UBBL – 2016.
2. Discharge from the staircases is not in accordance with clause 4.4.2.4.3.1 of NBC-Part-4, 2016.
3. Exits are not arranged in accordance with clause 7.8.3 of UBBL – 2016.

Therefore, plans are rejected.

Yours faithfully


26/9/2025
(Virendra Singh)

Chief Fire Officer

Ph. 011 - 23414333

