

0147

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/2025/SZ/ 320

Dated: 03/07/2025

To

Sh. A B K Singh (Commandant),
16 Bn NDRF, RRC Dwarka,
Near Dada Dev Mandir, Sector-07,
Dwarka, New Delhi-110077

Sub: **Regarding issuance of Fire Safety Certificate in r/o Administrative Block and GO's Mess located at Plot No. 14, Sector-08, Dwarka, New Delhi.**

Sir,

Please refer to your letter No. Engg/16 Bn/NDRF/RRC Dwarka/3066 dated 19/03/2025 received in this department vide outdoor diary No. 2217 dated 28/05/2025. In this connection, it is to inform you that the above-mentioned premise was inspected by the officers concerned of this department on 21/06/2025 in the presence Sh. Vikash (JE/E) to verify the compliance of shortcomings issued by this office vide letter No. F6/DFS/MS/SZ/2024/206 dated 19/04/2024. During course of the inspection, the shortcomings observed are as below.

1. Pressurization of lift shaft and lift lobby are not yet provided.
2. Basement is used for workshop & offices.
3. Waste material stored in basement is a fire hazard.

In view of above, application for issuance of fire safety certificate cannot be considered at this state. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

[Handwritten signature]