



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/BP/2025/492

Dated: 10/10/2025

To

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th Floor, Civic Centre, JLN Marg,
New Delhi- 110002.

Sub:- **Rejection** of building of building plans from fire safety point of view in r/o Industrial Occupancy at Plot No. 17/3, Block-B, Okhla Industrial Area Phase-II, New Delhi

Sir,

With reference to request ID no. 10120890 dated 26.09.2025 on the subject cited above; it is informed that the referred online building plans in respect of proposed construction of industrial building at Plot No. 17/3, Block-B, Okhla Industrial Area Phase-II, New Delhi were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcoming was observed:-

1. Segregation with slab in the staircases are not proposed between the basement and the stilt floor.

In view of the above, the building plans are **rejected** with a request to resubmit plans after rectification of above shortcoming for further consideration in the matter.

Yours faithfully,

(M. K. Chattopadhyay)
Dy. Chief Fire Officer