



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No. F.6/DFS/MS/Ind/NDZ/2026/ 334

Dated: 03/08/2026

To,

Sh. Madan Mittal,
Plot No.270, FIE Patparganj, Industrial Area,
Delhi-110092

**Subject: - Regarding renewal of Fire Safety Certificate in r/o Plot No.270, FIE Patparganj,
Industrial Area, Delhi-110092**

Sir,

This has a reference to online application id no. **52026060403394** dated 06/06/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 21/07/2026 in presence of Sh. Madan Mittal. The building is comprised of basement, stilt, ground plus two upper floors. The following shortcomings were observed during the time of inspection.

1. Major addition/alteration at stilt of the building. Approval of building department is required.
2. Second staircase's exit is locked at all floors.
3. Smoke management systems are not provided in basement and upper floors.
4. First-aid-Hose Reels are provided but not functional.
5. Exit Signages are found removed.

In view of above, **the application for renewal of Fire Safety Certificate is not considered at this stage.** The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

**(Dr. S. K. TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE OFFICER**

Copy to:-

1. The Executive Engineer (Bldg.) HQ, MCD,419, Patparganj Industrial Area, Delhi-110092, w.r.t online request MCD ID No. **52026060403394**