

C-4

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F.6/DFS/MS/2025/ 486

Dated: 06 /10/2025

To

The Commissioner, MCD,  
Civic Centre, New Delhi

**Sub:- Regarding issuance of fire safety certificate in r/o M/s Plot No. 2 & B-25/2, Okhla Industrial Area Phase-II, New Delhi.**


Sir,

This has reference to MCD online I.D- 10120633, dated 20.09.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected jointly by the officer concerned of this department on 30/09/25 along with Mr. Rameshwar Meena JE, MCD and during the inspection following shortcomings were observed:-

1. Fire check doors at the staircases are not provided.
2. Alternate staircase is not available at first and second upper floors.
3. Pressurization/naturally ventilation of staircases is not provided.
4. Exit signage's. are not provided.
5. Fire extinguishers are not provided as per IS 2190.
6. Sprinklers in basement is not provided.
7. Hose reel and pump found non-functional.
8. Overhead tank of 5000 liter is provided against the requirement of 25,000 liter.
9. Instead of one pump of 900 LPM capacity, one pump of 450 LPM capacity is provided.
10. Smoke management system in basement is not provided.
11. Standby power supply is not provided.

In view of above, the case is rejected and FSC cannot be issued till compliance of above shortcomings at the earliest for further consideration in the matter.

Yours faithfully

  
(A. K. Malik )  
Dy. Chief Fire Officer  
Delhi Fire Service