



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F. 6. / DFS / MS / BP / 2025/413

Dated: 22 /08/2025

To,
The Executive Engineer -I (Bldg.)HQ,
Municipal Corporation of Delhi,
9th Floor, Civic Centre, Minto Road,
New Delhi – 110002.

Sub:- Online building plans in r/o Construction of Residential Group Housing at Plot No. ID-3753, Pocket-A-2, Sector-17, Dwarka, New Delhi.

Sir,

Please refer your online ID No. 10120704 dated 08/08/2025 on the subject cited above. In this connection it is to inform you that the referred online building plans have been examined and observed that there is a proposal of construction of two High-rise Residential Blocks, one low-rise EWS block & one low-rise Community Hall block at Plot No. ID-3753, Pocket-A-2, Sector-17, Dwarka, New Delhi. During scrutiny following shortcomings are observed:

1. The placement of exits in tower-1 is not in accordance with clause 7.8.3 of UBBL – 2016.

Therefore, plans are rejected.

Yours faithfully


22/8/2025

(Virendra Singh)
Chief Fire Officer
Ph.: 011-23414333

