

c/s2

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6 /DFS/MS/BP/2025/ 422

Dated: 26/08/2025

To,

Dr. Kusum Arora
Medical Superintendent -Nursing Home
DGHS, 3rd Floor, Delhi Government Dispensary Building,
S-1, School Block, Shakarpur, Delhi-110092.

Sub: Clearance from fire safety point of view in r/o Plot No. 3 or 4, Block H, Bali Nagar, New Delhi-110015.

Sir,

Please refer your letter No. F.24/310/W/DGHS/NHC/2025/495 dated 10/07/25 on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of construction of institutional (Hospital) building at Plot No. – 3&4, Block H, Bali Nagar, New Delhi-110015.

Following shortcoming is observed:

1. At some location corridors are proposed 02m which is against the requirement of 2.4m as per clause 7.11.2(e) of UBBI-2016.
2. Corridors/passageway is not proposed as per clause 7.11.2(e) of UBBL-2016.

Accordingly, the case is hereby rejected.

Yours faithfully,


25/8/2025
(Virendra Singh)
Chief Fire Officer
Ph. 011-23412225

