

c/s0

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/2025/ 328

Dated: 09/07/2025

To

Authorized Signatory,
For Truenorth Automobiles Private Limited,
A-73 Naraina Industrial Area Phase-I,
New Delhi.

Sub:- Regarding issuance of fire safety certificate in r/o Plot no. 73, Block No. A, Naraina Industrial Area, Phase -I, New Delhi.

Sir,

This has reference to your letter no. nil dated 19.06.2025 & DFS diary no. 2908 dated 19.06.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 01/07/2025 in the presence of Manager and the following shortcomings were observed:-

1. Hydrant, hose reel & pump found nonfunctional.
2. Pressurization of lift/ lift lobby & Staircases is not provided.
3. Alternate staircase serving to basement is not available to other parts as basement is divided in two parts through wooden partition.
4. Temporary shed at terrace floor is added, required to be removed or sealed.

In view of above, the FSC cannot be renewed till compliance of above shortcomings at the earliest for further consideration in the matter. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :
The Commissioner, MCD, Civic Centre, New Delhi.