



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c-9
75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/BP/2024/ 01

Dated: 01/01/2025

To,

The Executive Engineer (Bldg.) HQ,
Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area,
Delhi-110092.

**Sub: - Conditional approval of building plans from fire safety point of view in r/o Plot No 81,
Defence Enclave, Vikas Marg, Delhi-110092.**

Sir,

Please refer your online request ID No. 10119826 dated 19/12/2024 on the subject cited above. In this connection this is to inform you that the matter has been examined and observed that the shortcomings issued vide this office letter No. F.6/DFS/MS/BP/2024/681 dated 17.12.2024 (Copy enclosed) are not yet complied in totality.

In view of the above, the case is rejected.

Yours faithfully,

(Atul Garg)
DIRECTOR

011 - 23414000

Bl c 3

C18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/BP/2024/ 681

Dated: 17/12/2024

To

The Executive Engineer (Bldg.) HQ,
Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area,
Delhi-110092.

Subject: - Examination of building plans from Fire Safety point of view in r/o
proposed building at Plot No. 81, Defence Enclave, Vikas Marg, Delhi-
110092.

Sir,

Please refer your online request ID. No. 10119748 dated 11/12/2024 of online
building plans, on the subject cited above. In this connection, this is to inform you that
the building plans have been scrutinized by this department from fire safety point of
view and following shortcomings are observed: -

1. Water curtain is not proposed for Hydraulic car lifts as per UBBL-2016/ NBC
Part-IV, 2016.
2. Building plans were not submitted as per clause 2.0.4 of UBBL-2016.

In view of the above, the building plans are hereby rejected.

Yours faithfully

(Atul Garg)
Director

011 23414000

OP C M