



chir

7/11/25
AZOIKS
Anil Mahapatra

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2025/WZ/CC/40

Dated: 24/11/2025

FIRE SAFETY CERTIFICATE

Certified that Coaching Centre located at Plot No. 866, Dr. Mukherjee Nagar, Delhi-110009, building comprised of Ground & Three Upper Floors (Coaching Centre) only owned / occupied by Dhampur Polymers Pvt. Ltd., have complied with the fire prevention and Fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 11/11/2025 in presence of Mr. Satish and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 24/11/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Subject to conditions printed below.

Issued on 24/11/2025 at New Delhi by.

(Signature)
24/11/25
(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

(Signature)

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, JLN, Delhi-110002 (w.r.t. online ID-70000234)
2. Sh. Satish, Coaching Centre, Plot No. 866, Dr. Mukherjee Nagar, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularization's of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.DelhiGovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Coaching Centre, Plot No. 866, Dr. Mukherjee Nagar, Delhi-110009.
2. Type of Occupancy : Educational, Group-B(Coaching Centre)
3. Building comprised of : Ground & Three Upper Floors (Coaching Centre)
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives Letter No. : NBC (Part-IV)
7. Date of inspection : 11/11/2025
8. Name of the Inspecting Officer: Suman Kumar, A.D.O (SPM) & A.K. Jaiswal, D.O. (NW)
9. Name and designation of Officer from the building side : Sh. Satish
10. Year of Construction : 2024-25
11. Applicant's online MCD ID no.: 70000234

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC /UBBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 M	Provided	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	2	2	MR
	e. Width Of Corridor	1.50m	Provided	MR
	f. Door Size	1.20m	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	12	20	M/R
	• Types	ISI marked	Provided	M/R
	• IS marking	Required f A	Provided	M/R

N/2

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100mm	Provided	MR
	• Number of hydrants per floor	One	Provided	MR
	• Hose Box	One	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	10,000 Ltr.	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is **recommended** to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name : Suman Kumar
Designation : A.D.O. (SPM)

Signature of the Inspecting Office
Name : Ashok Kumar Jaiswal
Designation : D.O. (NW)

Dy. CFO (WZ)

Principal Director

Dy. CFO (F&W)

21/11

Dy. CFO (WZ)

21/11/25

NO (H&D)

Dy. CFO to Secy.

19/11/25