



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

c/21
स्वास्थ्य भारत
एक कदम स्वच्छता की ओर

No. F.6/DFS/MS/2025/SZ/ CC | 96

Dated: 22/08/2025

To

The Executive Engineer (Bldg.), HQ,
Municipal Corporation of Delhi,
9th Floor, Civic Centre, Minto Road,
New Delhi-110002

Sub: Issuance of Fire Safety Certificate in r/o **Coaching Centre Building** at Plot No. 8, Gagan Vihar, Delhi-110092

Sir,

This is with reference to online request **ID No. 70000167 dated 18/07/2025**. In this connection, it is informed that the site was inspected by the officers concerned of this department on 31/07/2025 from fire & life safety point of view, in the presence of Md. Waseem (Owner) of the Coaching Centre. During course of inspection, **the shortcomings observed is as below.**

1. Smoke venting system not provided on upper floors.
2. First-aid hose reel provided found non-functional.
3. Exit signage's not provided at conspicuous places in escape route.
4. Lift lobby not found provided in basement.
5. Lift signage's not found provided.

In view the above non-compliance, application for **issuance of fire safety certificate cannot be considered at this stage & rejected**. The occupancy of the building/premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier/management.

Yours faithfully,

21/8/2025

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Nodal Officer, Delhi Fire Service with the request to upload on online portal.