



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F.6/DFS/MS/BNQT/2025/WZ/134

Dated: 29/07/2025

To,

Sh. Gaurav Vij  
M/s Blessings The Banquet (A Unit of Radiant Cold Drinks Pvt. Ltd.)  
Plot No. 09, Road No. 42, Community Center,  
Pitampura, New Delhi-110034.

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Blessings The Banquet (A Unit of Radiant Cold Drinks Pvt. Ltd.) located at Plot No. 09, Road No. 42, Community Center, Pitampura, New Delhi-110034.**

Sir,

This has a reference to MCD online application ID No. **2025062610611** dated 26/06/2025 on the subject cited above. In this connection, it is to inform you that the said premises was re-inspected by the officer concerned of this department on dated 19/07/2025 in presence of Manager and During the inspection it was observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/BNQT/NDZ/2025/106 dated 06/06/2025 (copy enclosed) have not been complied yet.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

*V Singh*  
28/7/2025

(VIRENDRA SINGH)  
2. CHIEF FIRE OFFICER

Encl. As above

Copy to:-

MCD online portal ID **2025062610611** dated 26/06/2025



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

C-52  
7/6  
आपदादीन  
अमृत महोत्सव

No. F6/DFS/MS/BNQT/NDZ/2025/ 106

Dated: 06/06/2025

To,

Mr. Shankar (Manager),  
M/s Blessing The Banquet (A Unit of Radiant Cold Drinks Pvt. Ltd.),  
Plot No. 09, Road No. 42, Community Center, Pitampura,  
Delhi - 110034.

**Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Blessing The Banquet (A Unit of Radiant Cold Drinks Pvt. Ltd.) located at Plot No. 09, Road No. 42, Community Center, Pitampura, Delhi - 110034**

Sir,

This has a reference to your MHA Portal application No. 2025051508497 dated 17/05/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 24/05/2025 in the presence of Mr. Shankar (Manager) and observed that building comprised of Basement, ground plus one upper floor but banquet hall is running on ground floor only.

**Following shortcomings were observed during time of inspection:**

1. Banquet hall found operational in basement & ground floor and kitchen in first floor with temporary shed. Whereas banquet hall is permitted only in ground floor.
2. Additional temporary construction on first floor shall be demolished.
3. Smoke management system in basement floor found non functional.
4. MOEFA found provided but not functional.
5. P.A system found provided but not functional.
6. Terrace level pump of capacity 450 LPM provided against the requirement of 900 LPM.

In view of above shortcomings, the application for issuance for Fire Safety Certificate at this stage is rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully,

*Virendra Singh*  
5/6/2025

(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of police (Lic), 1<sup>st</sup> Floor, P. S. Defence Colony, New Delhi-110024. w.e.f.- MCD Portal application No. 2025051508497 dated 17/05/2025.
2. The Dy. Health Officer, Keshavpuram Zone, A-1, Public Health Department, MCD, Keshavpuram, Delhi-110035.