

c/14



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/BP/2025/ 207

Dated: 05/05/2025

To,

Mrs. Pooja Goel,
 H. No. 11, Block-BD,
 Pitampura, Delhi – 110034.

Sub:- Regarding clearance for fire of the building plan in respect of Plot No. A-1 – 167 (Second + Third Floor) Janak Puri, New Delhi.

Sir,

Please refer your letter No. Nil dated Nil on the subject cited above. In this connection it is to inform you that the building plan, as submitted by you has been examined and observed following shortcomings:

1. Alternate staircase is not provided.
2. Width of available staircase is not marked on the plan.
3. Entry to lift is not through fire check door.
4. Entry to staircase in basement is not through fire check door.
5. Car lift is not segregated.
6. Terrace plan of third floor is not provided.
7. Staircase is not serving the terrace of third floor.
8. Fire safety measures such as underground & overhead fire water tank, pump room etc. are not marked on the plan.
9. Intended use of floors is not specified.
10. Door window schedule is not provided.

Therefore, you are requested to rectify the above shortcoming and resubmit the plans for further consideration in the matter.

Yours faithfully


 21/5/25

(Dr. S.K. Tomar)
 Dy. Chief Fire Officer
 Ph. 011-23412025



Copy to:

The Executive Engineer (Bldg.),
 Municipal Corporation of Delhi,
 West Zone, Second Floor,
 Dr. Sahib Singh Verma Nigam Bhawan,
 Shivaji Enclave, New Delhi – 110027.