

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6 /DFS/MS/BP/2025/ 87

Dated: 28/02/2025

To,

The Dy. Director (Bldg.),
DDA, INA, Vikas Sadan,
New Delhi -110023.

Sub: Clearance from fire safety point of view in r/o Plot No. D-110, Keshopur Industrial Area, New Delhi -110018.

Sir,

Please refer your online request ID No.-KP/0109/2024 dated 20.02.2025, on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed following shortcomings:

1. 6m wide road all around the buildings is not proposed as per clause 8.2 of UBBL-2016.
2. Exit doorways are not provided as clause 7.12.5 of UBBL-2016.

Accordingly, the case is hereby rejected.

Yours faithfully,


(Atul Garg)
Director
011-23414000

W c D