

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2025/BP/ 14

Dated: 03/01/2025

To,

The Asstt. Engineer (B)
Building Department- II, Central Zone,
Municipal Corporation of Delhi,
Lajpat Nagar, New Delhi.

Subject: Regarding clearance from fire safety point of view in r/o regularization of excess coverage in Plot No. G-3, Block-B-1, Mohan Cooperative Industrial Estate, Mathura Road, New Delhi.

Sir,

Please refer your letter No. D 53/AE(B)-I/CNZ/2024 dated 12.12.2024 and D - 513/AE(B)-I/CNZ/2024 dated 12.12.2024 respectively, on the above cited subject. In this connection, this is to inform you that the matter is examined and following shortcomings are observed.

1. All around 06 meter motorable road with 09 m turning radius for fire tender movement is not meeting requirement as per clause 8.2 of UBBL 2016.
2. The fire tower as per clause 9.3.13/ 1.4.46 of UBBL 2016 is not proposed.

Accordingly case is rejected and returned back in original.

Encl: as above

Yours faithfully

(Atul Singh)

Director

011 23414000

1/c Janki 25