



C18  
THE NEW PATENT OF DELHI

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/School/2025/NDZ/ 1048

Dated: 22/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the PM Shri Kendriya Vidyalaya located at Shahdara, Delhi- 110032, comprised of Ground Plus Three Upper Floors owned/occupied by PM Shri Kendriya Vidyalaya was issued FSS vide letter no. F.6/DFS/MS/School/2022/NDZ/1357 dated 27/12/2022. The premises was re-inspected by the officer concerned of this department on 08/08/2025 in the presence Mrs. Neetu Verma, Principal and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" (Group-B) with effect from 22/08/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010& also conditions printed below.

Issued on: 22/08/2025 at New Delhi by.

  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER

To,

The Principal, PM Shri Kendriya Vidyalaya located at Shahdara, Delhi- 110032

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/07

1. Name & address of the building : PM Shri Kendriya Vidyalaya,  
Shahdara, Delhi- 110032,
2. Building is comprised of :Ground plus three upper floors
3. Type of Occupancy :Educational
4. Type of Case :**Renewal**
5. Details of Previous NOC letter :F.6/DFS/MS/School/2022/NDZ/1357dated 27/12/2022
6. Fire Safety direction letter No :F.6/DFS/MS/BP/2019/267 dated 26/07/2019
7. Date of Inspection : 08/08/2025
8. Name of the Inspecting officers :ADODepak Kumar
9. Name and designation of Officer  
from the building side : Mrs. Neetu Verma (Principal)
10. Year of Construction :2021
11. Applicant's letter No :K.V. Shahadra/2025-26/91dated 05/07/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Directive Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	• Road width	12 mtr.	12 mtr.	MR
	• Gate width	06 mtr	06 mtr	MR
	• Width of internal road	06 mtr	06 mtr	MR
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 nos.	02 nos. + Ramp	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr.	1.50 mtr& 02 mtr ramp	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 nos.	01 nos.	MR
	e. Width of Corridor	1.50 mtr.	2.40 mtr	MR
	f. Door Size	1.20 mtr.	1.20 mtr.	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	Required	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	12 a/c per hrs.	Ventilated	MR



05.	Fire Extinguishers			
	• Total numbers	18nos.	20nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	02nos	02nos	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA			
09	Public address System.			
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	02 nos.	02 nos.	MR
	• Hose Box	02 nos.	02 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	900 LPM	900 LPM x 02	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

49,

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	25,000 ltr	25,000 ltr	MR
	• Overhead Tank capacity	Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	Required	Provided	MR
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided in all LT & HT Panels	MR
20	Special Fire Protection systems for protection of special Risks, if any:			

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Rules. The FSC issued vide letter No. F.6/DFS/MS/School/2022/NDZ/1357 dated 27/12/2022 **renewal under rule 37 of the Delhi Fire Service Rule, 2010 is recommended.**

*Deepak*  
08/08/2025  
Signature of the Inspecting Officer  
Name : - Deepak Kumar  
Designation : - A.D.O (Shd)

DO/ED) *AKJ*  
11/08/2025  
By C.F.O. (NDZ) *div*  
11/08/25  
C.F.O.  
16/8/2025  
Principal Director  
A.D.O (Shah)  
C.F.O.  
18/08/25