

C 27

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No.F.6 DFS/MS/School/2025/SZ/65

Dated: 24/01/2025

FIRE SAFETY CERTIFICATE

Certified that the **PM SHRI Kendriya Vidyalaya NMR, JNU Campus** at Old JNU Campus, New Mehrauli Road, New Delhi 110067 comprised of Ground plus Two upper floors owned/occupied by Kendriya Vidyalaya was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2022/SZ/49 dated 17-01-2022. The said premise was re-inspected by officer concerned of this department on 17/01/2025 in presence of Mr. Chandan Kohli and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building is fit for occupancy class "**Educational Building Group - B**" with effect from 24/01/2025 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 24/01/2025 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Kendriya Vidyalaya at NMR, JNU Campus, New Delhi 110067
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi -54

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

2/13

INSPECTION REPORT

1	Name & Address of the Building	Kendriya Vidyalaya at NMR, Old JNU Campus, New Delhi 11067		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground plus Two upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2022/SZ/49 Dt. 17-01-2022		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	17-01-2025		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Chandan Kohli		
10	Year of construction	1978		
11	Applicant letter No.	F.1430/KV/JNU/2024-25 dated 01/01/2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<div style="text-align: center;">Accessible</div> <div style="text-align: center;">Required</div> <div style="text-align: center;">-NA-</div>	<div style="text-align: center;">Approachable</div> <div style="text-align: center;">Provided</div> <div style="text-align: center;">-NA-</div>	<div style="text-align: center;">MR</div> <div style="text-align: center;">MR</div> <div style="text-align: center;">-NA-</div>
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors. ➤ Basement floor. 	<div style="text-align: center;">Required</div> <div style="text-align: center;">-NA-</div>	<div style="text-align: center;">03 Nos + 01 ramp</div> <div style="text-align: center;">-NA-</div>	<div style="text-align: center;">MR</div> <div style="text-align: center;">-NA-</div>
	b) Width of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors ➤ Basement floor 	<div style="text-align: center;">Required</div> <div style="text-align: center;">-NA-</div>	<div style="text-align: center;">1.5 m each + 1.50 m ramp</div> <div style="text-align: center;">-NA-</div>	<div style="text-align: center;">MR</div> <div style="text-align: center;">-NA-</div>
	c) Protection of exits			
	<ul style="list-style-type: none"> ➤ Fire check door ➤ Pressurization 	<div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div>	<div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div>	<div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div>
	d) No. of continuous staircase to terrace	<div style="text-align: center;">Required</div>	<div style="text-align: center;">02 Nos</div>	<div style="text-align: center;">MR</div>
	e) Width of corridor	<div style="text-align: center;">-NA-</div>	<div style="text-align: center;">-NA-</div>	<div style="text-align: center;">-NA-</div>
	f) Door size	<div style="text-align: center;">1m</div>	<div style="text-align: center;">Provided</div>	<div style="text-align: center;">MR</div>
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	<div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div>	<div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div>	<div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div>
4	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	<div style="text-align: center;">30 ACPH</div> <div style="text-align: center;">12 ACPH</div>	<div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div>	<div style="text-align: center;">-NA-</div> <div style="text-align: center;">-NA-</div>
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	<div style="text-align: center;">29 Nos</div> <div style="text-align: center;">ABC / CO2</div> <div style="text-align: center;">ISI marked</div>	<div style="text-align: center;">29 Nos</div> <div style="text-align: center;">ABC & CO2</div> <div style="text-align: center;">Provided</div>	<div style="text-align: center;">MR</div> <div style="text-align: center;">MR</div> <div style="text-align: center;">MR</div>
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	<div style="text-align: center;">03 No</div> <div style="text-align: center;">30m</div> <div style="text-align: center;">5mm</div>	<div style="text-align: center;">Provided</div> <div style="text-align: center;">Provided</div> <div style="text-align: center;">Provided</div>	<div style="text-align: center;">MR</div> <div style="text-align: center;">MR</div> <div style="text-align: center;">MR</div>
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	<div style="text-align: center;">-NA-</div>	<div style="text-align: center;">-NA-</div>	<div style="text-align: center;">-NA-</div>

b

-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
MR
MR
MR
MR
-NA-
-NA-
-NA-
-NA-
MR
MR
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-
-NA-

2/15

	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.			-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2022/SZ/49 Dt. 17-01-2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

13/1/25

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

20/1/25
21/01/2025
21/1/25
Any bit

As approved, F.T. letter is put up for your signature A

23/1

Director
2/1/25