



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 51

Dated: 22 / 01 / 2025

To

The Principal,
PM Shri Kendriya Vidyalaya,
Andrews Ganj, New Delhi-110024

Sub: **Renewal of Fire Safety Certificate in r/o PM Shri Kendriya Vidyalaya located at Andrews Ganj, New Delhi-110024**

Sir,

This has a reference to the email received from Id. pmshevikvandrewsganj@kvsdelhi.in dated 09/12/2024, on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on dated 10/01/2025 in your presence from fire safety point of view. During course of inspection, the shortcomings observed are as below: -

1. Hose-reel hose found non-functional.
2. Terrace level pump was not on auto mode.
3. Exit signage's found removed at some locations.

In view of the above, application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further consideration in the matter. The occupancy of the premise/building in the absence of requisite fire safety arrangements shall be at the risk and responsibility of school management.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

01/01/25