



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2025/WZ/School/ 1180

Dated: 23/09/2025

FIRE SAFETY CERTIFICATE

Certified that the Pole Star Public School, Sector-2, Rohini, Delhi-110085, comprised of Basement + Ground + 02 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/2010/1195 dated 23.04.2010. The premises was re-inspected by the officer concerned of this department on 02.09.2025 in the presence of Mrs. Upasana and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class 'Group B Educational' with effect from 23/09/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/09/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Pole Star Public School, Sector-2, Rohini, Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Pole Star Public School, Sector-2, Rohini, Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Basement + Ground + 02 upper floors**)
4. Details of Previous NOC : F.6/DFS/MS/2010/1195 dated 23.04.2010.
5. Fire Safety directives letter No : NBC Part-IV.
6. Date of inspection : 02.09.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mrs. Upasana
9. Year of Construction : 2009
10. Applicant's letter No. : OD No.4683 dated 08.08.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width 	Accessible	Accessible	MR
	<ul style="list-style-type: none"> Gate width 	Accessible	4.5m	MR
	<ul style="list-style-type: none"> Width of internal road 	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	02nos.	02nos.	MR
	<ul style="list-style-type: none"> Basements 	02nos.	02nos.	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor 	1.5m	1.5m & 1.20m iron staircase	MR (Old case)
	<ul style="list-style-type: none"> Basements 	1.5m	2 x 1.5m	MR
	c. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> Pressurization 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	01nos.	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sealing of electrical shafts 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire Rating of shaft door 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Water Curtain 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire Dampers 	-NA-	-NA-	-NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	Exhaust fan	MR
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural ventilation/ Exhaust fan	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	15nos.	16nos.	MR
	<ul style="list-style-type: none"> Types 	ABC/CO2	ABC-16	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	01nos.	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30mm	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		180lpm	180lpm provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450lpm	450lpm	MR
		40m	40m	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		5000ltr	5000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

N/14

19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 96 dated 27.02.2023, the FSC issued vide letter no. **F.6/DFS/MS/2010/1195 dated 23.04.2010**, renewal of FSC under rule 37 of the Delhi Fire Service Rules, 2010 is **recommended**.

[Signature]
 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)

DO (NW) - NW

~~DCFO (W2)~~

Kindly appraise. Jockey pump cap. 180 LPM
 is connected with ground level tank or not
 & What is the Capacity of the tank?

DCFO/425-N/12

Dated 10-09-25

ADO (Rohini)

[Signature]
 10/9/2025

Jockey pump is connected adjacent to
 surface pump only, not on g.f.

Resubmitted please.

DCFO/425-N/12

Dated 16/09/25

~~DCFO (W2)~~

[Signature]
 10/9/2025

CFO
[Signature]
 18/9/2025
 Principal Director

CFO to SSM.

ADO (Rohini)
[Signature]
 18/09/25