



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/Banquet/2025/ 84
To,

Dated: 15/05/2025

Mr. Ved Prakash (Authorized Signature),
M/s Pooth Haveli Banquet,
located at Kh. No.154,
Plot No.385, Phirni Road,
Pooth Khurd,
Delhi-110039.

Sub: Issue of FSC in r/o M/s Pooth Haveli Banquet located at Kh. No.154, Plot No.385, Phirni Road, Pooth Khurd, Delhi-110039.

Sir,

Kindly reference to letter received in this department through outdoor diary no. 273 dated 07.04.2025 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 24.04.2025, in presence of **Mr. Asish Jindal** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. FCD is not provided in one staircase at 2nd floor.
2. Sprinkler is not provided on 3rd floor.
3. Smoke management system is not provided basement & ground floor.
4. Basement is use for banquet hall.
5. Staircase pressurization lift & lift lobby found removed.
6. Pump house is not accessible due to storage of malwa other items & water tank leakage.
7. The required exit signage are not provided.
8. Sprinkler at some places found missing & not installed as per BIS 15105.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000