



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/CGHS/2025/SZ/ 290

Dated: 16/06/2025

To

The President / Secretary,
M/s Prabha CGHS Ltd,
Plot No. 11, Sector-23,
Dwarka, New Delhi-110077

Sub: Renewal of Fire Safety Certificate in r/o M/s Prabha CGHS Ltd located at Plot No. 11, Sector-23, Dwarka, New Delhi-110077 from fire safety point of view.

Sir,

Please refer to your letter No. Nil dated 26/05/2025 received through outdoor diary No. 2126 dated 27/05/2025. In this connection, the above-mentioned residential building has been inspected by the officer concerned of this department on 03/06/2025 in your presence from fire safety point of view. During course of inspection, the shortcomings observed are as below: -

1. First aid hose-reel provided found non-functional at some places.
2. Some of the hydrants found non-functional as indicated during inspection.
3. Terrace Pumps provided found non-functional & not in auto mode.
4. Overhead water tanks provided but some found empty.
5. Lift signage's found removed at some places.

In view of the above, application for issuance of fire safety certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further action in the matter. The occupancy of the building/premises without valid Fire Safety Certificate shall be at the risk and responsibility of the management committee.

Yours faithfully,

(ATUL GARG)
DIRECTOR
Ph. 011-23414000

Copy to: -

1. The Joint Director (L&I), Building, DDA, Vikas Sadan, INA, New Delhi-110023