



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

75
आज़ादी का
अमृत महोत्सव

No. F. 6. / DFS / MS / BP /CGHS/2025/ 308

Dated: 24 /06/2025

To,

The Dy. Director (L&I) Bldg.,
Delhi Development Authority,
Vikas Sadan, INA,
New Delh-110023.

Sub: Online building plans belonging to Prabha CGHS Ltd. at Plot No. 11, Sector-23, Dwarka, New Delhi-110077 for addition & alteration.

Sir,

Please refer your online File No. DW23P/0069/2024 dated 04.06.2025 on the subject cited above. In this connection it is to inform you that the referred building plans have been scrutinized by this department from life/fire safety point of view and observed following shortcomings:

1. 6.0 meter wide fire tender movement road, all around the high-rise blocks, is not marked on the layout plan in accordance with previous sanctioned layout plan dated 13.03.97.
2. Width of staircases is not marked on the plans.

Therefore, plans are rejected.

Yours faithfully

(ATUL GARG)
DIRECTOR

PH. 011-23414000

[Signature]

[Signature]

[Faint handwritten notes]