

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2024/WZ/Collage & Inst./ 09

Dated: 19/02/2025

FIRE SAFETY CERTIFICATE

Certified that the **Pradeep Memorial, Comprehensive College of Education** located at **Pratap Vihar, Kirari Extn. Nangloi, Delhi-110086**, comprised of **Ground + 03 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2021/WZ/School/Collage& inst./18** dated **30.11.2021**. The premises was re-inspected by the officer concerned of this department on **30.01.2025** in the presence of **Mr. Deepak (Chairman)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational (Group-B)** with effect from 19/02/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/02/2025 at New Delhi by

**(Atul Garg)
DIRECTOR**

Ph; 011-23414000

Copy to :-

1. The Chairman, Pardeep Memorial, Comprehensive College of Education located at Partap Vihar, Kirari Extn. Nangloi, Delhi-110086.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

INSPECTION REPORT

1. Name & address of the building	Pardeep Memorial, Comprehensive College & Education located at Pratap Vihar, Kirari Extn. Nangloi, Delhi-110086.
2. Type of Occupancy	Educational
3. Type of Case	Two new blocks- (Gr. + 01 upper floor under construction & 2 nd new block- Gr. + 03 upper floors under construction) & Renewal of Old block (Ground + 03 upper floors only)
4. Details of Previous NOC	F.6/DFS/Ms2021/WZ/School/Collage & inst./18 dated 30.11.2021.
5. Fire Safety directives letter No	NBC Part-IV
6. Date of inspection	30.01.2025.
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)
8. Name and designation of officers From the building side	Mr. Deepak (Chairman)
9. Year of Construction	2001
10. Applicant's letter No.	Online e-mail dated 29.01.2025.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Rule 35 (6)	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	6.0m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	g. Number of staircases			
	• Upper Floors	02nos.	02nos. & 01 ramp	MR
	• Basements	-NA-	-NA-	-NA-
	h. Width of staircases			
	• Upper Floor	1.5m	Provided	MR
	• Basements	-NA-	-NA-	-NA-
	i. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	02nos.	Provided	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1.0m	Provided	MR
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers			
	• Total numbers	24nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR

	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01nos.	Provided	MR
	• Hose Box	01nos.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm & 180lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	25,000ltr	Provided	MR
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-

		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 377 dated 10.12.2021, the FSC issued vide letter no. F.6/DFS/MS/2021/WZ/School/Collage & inst./18 dated 30.11.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended. As renewal of previous fsc, therefore plans are not required.

Signature of the Inspecting Officer
Name: Ajay Kumar Sharma
Designation ADO (Rohini)

D.B Mukherjee
DO (NW)

[Signature]
14/02/2025

[Signature]
14/02/2025

[Signature]
14/2/25

[Signature]
14/2/25

[Signature]
18/02/25

[Signature]

FT letter is put up
for kind perusal &
Signature please.

[Signature]
15/2/25

DCFO... 10/14/2025
Date... 14/12/2025