



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-4,
DELHI
FIRE SERVICE
NEW DELHI-110001

No: F.6/DFS/MS/School/2026/NZ/ 758

Dated: 06/08/2026

To,

The Principal,
Pratibha Public School,
Kh. No. 146, Old Managal Bazar Wali Gali,
Burari, Delhi- 110084.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Pratibha Public School located at Kh. No. 146, Old Mangal Bazar Wali Gali, Burari, Delhi- 110084.


Sir,

This has reference to your letter no. nil dated 07/07/2026 received through outdoor diary no. 3438 dated 07.07.2026 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 23.07.2026 in presence of Sh. Kamal Dubey to see the compliance of requisite fire safety measures. During the course of inspection, it is observed that school is running at Ground floor only in a building is comprised of Ground plus first floor. Your request for issuance of FSC is rejected due to the following shortcomings:

1. Class room door width found 0.90 m against the required width of 1.20 m.
2. Building plan in a scale of 1:100 duly signed by registered architect and owner is not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully


(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service


Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, Delhi.