



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI**

No. F6/DFS/MS/School/WZ/2025/ 796

Dated: 17/06/2025

FIRE SAFETY CERTIFICATE

Certified that the Presidium Punjabi Bagh (Shri Narender Charitable Trust), located at 11/77, West Punjabi Bagh, New Delhi-110026, in a building Comprised of Basement, Ground & 03 Upper Floors, Owned/Occupied by Presidium Punjabi Bagh (Shri Narender Charitable Trust). The premises was inspected by the officer concerned by the department on 26/03/2025 in the presence of Smt. Jagriti Chawla (School Head) and found that premise/building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Act 2007 and Delhi Fire Service Rules 2010, and found that the building / premises is fit for the occupancy class "Educational" (Group-B) with effect from ...17.06.2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on ...17.06.2025 at New Delhi.


(Atul Garg)
Director

Copy to:

1. The Principal, M/s. Presidium Punjabi Bagh (Shri Narender Charitable Trust), located at 11/77, West Punjabi Bagh, New Delhi-110026.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per Building bylaws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. **Owner/occupier has given an undertaking that not to use of lift in basement & sealed by brick wall if it is used FSC shall be null & void automatically.**

INSPECTION REPORT

nr 20

1. Name & address of the building	Presidium Punjabi Bagh (Shri Narender Charitable Trust), located at 11/77, West Punjabi Bagh, New Delhi-110026.			
2. Type of Occupancy	Educational (Basement + Ground + 03 Upper floors)			
3. Type of Case	New			
4. Details of previous NOC	Nil			
5. Fire Safety directives letter No	NBC Part -IV/D.O.E Circular No.-3298-3398 dated 01/03/2011			
6. Date of inspection	26/03/2025			
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)			
8. Name and designation of officers from the building side	Smt. Jagriti Chawla (School Head)			
9. Year of Construction	2007-08 (As per prev. inspection report dtd.- 27/02/2023)			
10. Applicant's letter No.	Outdoor diary No. 12388 dated -13/02/2025			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement /Circular No.-3298-3398 dated 01/03/2011/	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	03	MR
	• Basements	02	04	MR
	b. Width of staircases			
	• Upper Floors	1.5 mts	1.52 m, 1.25m, 1.5 m	MR
	• Basements	1.5 mts	1.80m, 1.52m, 1.25m & 1.20 to 1.5m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5m	Provided	MR
	g. Door Size	1 m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	50 Nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

h

7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	02	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 X 2 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

NOTE :- Owner/occupier has given an undertaking that not to use of lift in basement & sealed by brick wall if it is used FSC shall be null & void automatically.

The fire protection systems provided in the building were randomly test checked and found functional at the time of inspection. Earlier all the shortcomings issued by this department have been complied by the management of School.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

24/04/2015

16/4/2015

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

*5-ND
4/25*

21/4/2015

23/4/2015

01/05/2015

FT Ph.

Sir, F.T is not up for you kind personal copy
Directly