



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 417

Dated: -05/05/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Prince Palace Dx., 5115, Gali Thanedar Wali, Main Bazar, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026041304939 dated 13/04/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 22/04/2026 in the presence of Sh. Mukesh, Manager and following shortcomings were observed: -

1. Automatic operation of Fire Pump found removed.
2. Domestic connection in overhead water storage tank is not permitted.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


4/5/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

OIC BR

Copy to: -

1. The Manager, M/s Prince Palace Dx., 5115, Gali Thanedar Wali, Main Bazar, Paharganj, New Delhi - 110055.