

C/03

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2025/WZ/ 164

Dated: 19/03/2025

To,
The Principal,
Prince Public School,
located at Budh Vihar,
Delhi-110086.

Sub: Issue of FSC in r/o Prince Public School, located at Budh Vihar, Delhi-110086.


Sir,

This is in reference to your letter No. PPS/2024 dated 17.12.2024 received through outdoor diary no. 10423 dated 17.12.2024 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **06.03.2025** in presence of **Mrs. Purnima** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Smoke ventilation is not provided on upper floor & ground floor and staircases.
2. First aid fire protection systems e.g fire extinguishers etc in not provided in the building.
3. First Aid hose reel not provided
4. Terrace Fire pump with capacity of 450 LPM is not provided.
5. Auto starting/Manual stopping system of pumps not provided.
6. Over Head water captive tank of 10,000 ltrs is not provided.
7. Exit floor signage etc are not provided.
8. Form I along with a certificate from authorized architect in not provided.
9. Approved/as built building plans from authorized architect school building are not provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000
Oe
my