

Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

75
आज़ादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F. 6. / DFS / MS / BP / 2025/ 351

Dated: 28/07/2025

To,

The Executive Engineer, (Bldg) HQ,
Municipal Corporation of Delhi,
9th Floor Civic Centre, Minto Road,
New Delhi-110002.

Subject: Online building plans in r/o Property No. 11, Facility Centre, Mayapuri, New Delhi.

Sir,

Please refer your Request ID No. 10120737 dated 17/07/2025 on the subject cited above. In this connection this is to inform you that online building plans have been scrutinized by this department from fire and life safety point of view and observed following shortcomings:

1. Information, provided in CAF, is neither matching with the plans nor in accordance with UBBL- 2016 & NBC- Part-4, 2016.
2. Alternate staircase of 1.5-meter width is not proposed as per UBBL - 2016.

Therefore plans are rejected.

Yours faithfully



(Virendra Singh)

Chief Fire Officer

Ph. 011 - 23413339

