



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2025/SZ/285

Dated: 16 / 06 / 2025

To

The Executive Engineer (Bldg.), HQ,  
Municipal Corporation of Delhi,  
9<sup>th</sup> Floor, Dr. SPM Civic Centre,  
Minto Road, New Delhi-110002

**Sub: Renewal of Fire Safety Certificate in r/o Building at Property No. 112-113, Gautam Nagar, New Delhi-110029.**

Sir,

This has a reference to the letter received in this department through outdoor diary No. 1853 dated 20/05/2025, on the subject cited above. In this connection, it is to inform you that the said premise was re-visited by the officer concerned of this department on 31/05/2025 in the presence of Sh. Vinay Kumar (Technician) to verify the compliance of shortcomings communicated by this office vide letter No. F.6/DFS/MS/2025/SZ/121 dated 25/03/2025 and status of shortcomings observed is as below.

S. No.	Shortcomings issued	Present status
1.	One of the staircases found totally blocked and the railing of the staircases damaged/broken.	Not complied
2.	Standby fire pump Diesel found non-functional.	Not complied
3.	Hose-reel, hydrant & sprinklers found non-functional.	Partially complied
4.	Exit signage & lift signage found removed.	Not complied
5.	Lift under repair/rectification.	Not complied
6.	Basement found used for grocery sales, storage with blocked entry/exits	Not complied
7.	Coaching Centre of DAMS FMGE running at 2 <sup>nd</sup> floor.	Not complied
8.	Restaurant found running at stilt floor.	Not complied

In view of above, you are requested to verify usages of basement, stilt floor of the building from occupancy point of view and share your action taken report for further action at our end. The occupancy of the building in the absence of valid Fire Safety Certificate shall be at the risk and liability of the owner/occupier.

Yours faithfully,

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. Authorized Signatory, M/s Kapoor Sons & Co., AB1-1, Kamal Cinema Building, Safdarjung Enclave, New Delhi-110029