



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/WZ/2026/ 536

Dated: 10/06/2026

FIRE SAFETY CERTIFICATE

Certified that the Punjab Grill and You Mee (A Unit of Lite Bite foods Pvt Ltd), located at Shop No. F and B 308, 3rd floor, DLF Mid Town Plaza, Moti Nagar, Delhi-110015 building comprised of Three Basement + Ground + 04 Upper floors (Restaurant running at Third floor in DLF Mid Town). The building was inspected by the officer concerned of this department on 27/05/2026 in the presence of Mr. Vijay Sharma from building/premises side and found that the building/premises management have complied with the Fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire service Rules 2010, and that the said building / premises is fit for occupancy class Group-D "Assembly"(for Restaurant running at Third floor only) with effect from 10/06/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 Conditions mentioned below

Issued on10/06/2026..... at New Delhi by.


(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Commissioner, MCD, Civic Centre, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any: Online MCD Portal ID-2026040204126 dated 02/04/2026.
2. The Owner/Occupier, Punjab Grill and You Mee (A Unit of Lite Bite foods Pvt Ltd), located at Shop No. F and B 308, 3rd floor, DLF Mid Town Plaza, Moti Nagar, Delhi-110015.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

INSPECTION REPORT					
1	Name & Address of the building		Punjab Grill and You Mee (A Unit of Lite Bite foods Pvt Ltd), located at Shop No. F and B 308, 3 rd floor, DLF Mid Town Plaza, Moti Nagar, Delhi-110015.		
2	Building is comprised of		Three Basement + Ground + 04 Upper floors (Restaurant running at Third floor in DLF Mid Town)		
3	Type of occupancy		Eating House /Assembly Occupancy		
4	Type of case		New Case		
5	Details of previous FSC		F6/DFS/MS/2025/192 dated 22/04/2025 (DLF Mid Town)		
6	Fire safety direction letter no.		Nil		
7	Date of inspection		27/05/2026		
8	Name of the inspecting officers		Mohd. Firoz Khan, ADO/MN		
9	Name of the designation of officer From the building side		Mr. Vijay Sharma (Maintenance)		
10	Year of construction		2022 (As per MHA Portal)		
11	Applicant's letter no.		MCD Application No. 2026051506911 dated 16/05/2026		
The said restaurant is Running at third floor in DLF Mid Town in a building comprised of three basement, ground + four upper floors was issued FSC vide letter no. F6/DFS/MS/2025/192 dated 22/04/2025.					
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33		BBL / NBC Requirements	Provide at site	Remarks MR/NM R
1	Access to Building				
	A	Road width	06 m	Provided	MR
	B	Gate width	06 m	Provided	MR
	C	Width of internal roads	06 m	Provided	MR
2	Number, Width, Type & Arrangement of Exits				
	A	No. of staircase:			
		a)	Upper floor	2 nos.	Provided by mall
		b)	Basements	NA	NA
					Running at 3 rd floor
	B	Width of the staircase:			
		a)	Upper floors	1.5 mtr each	Provided by mall
		b)	Basements	NA	NA
	C	Protection of Exits			
		a)	Fire check door	NA	Provided by mall
		b)	Pressurization	NA	Provided by mall
	D	No. of continuous staircase to terrace:		Required	Provided by mall
	E	Width of the corridor		Required	Provided by mall
	F	Door size		1.5 m X 2	Provided by mall
3	Compartmentation:				
	A	Fire check doors		NA	Provided by mall
	B	Sealing of horizontal & vertical opening		NA	Provided by mall
	C	Fire rating of shaft doors		NA	Provided by mall
	D	Water curtain		NA	Provided by mall
	E	Fire dampers		NA	Provided by mall
4	Smoke management System:				
	A	Basements		NA	Provided by mall
	B	Upper floors		Required	Provided by mall
5	Fire Extinguishers				
	A	Total numbers		05 nos.	Provided
	B	Types		ABC & CO2	Provided
	C	ISI marking		ISI marked	Provided

6	First Aid Hose Reel Common with the Mall			
	A	Total no. at each floor	01 no.	Provided MR
	B	Length of hose reel	30 m	Provided MR
	C	Nozzle diameter	5 mm	Provided MR
7	Automatic Fire Detection and Alarm System			
	A	Type of detectors	Smoke & Heat	Provided & connected with the Mall MR
	B	Location of main Panel	Required at G.F.	Provided MR
	C	Location of repeater panel	Required	Provided MR
	D	Alternate power source	Required	Provided MR
	E	Hooter's location	Required	Provided MR
8	MOEFA		Required	Provided MR
9	Public Address System		Required	Provided by mall MR
10	Automatic Sprinkler System			
	A	Basement	NA	Provided by mall NA
	B	Upper floor	Required	Provided by mall MR
	C	Sprinklers above false ceiling	NA	NA NA
11	Internal Hydrants Common with the Mall			
	A	Size of the riser/down comer	150 mm	Provided MR
	B	No. of hydrants per floor	01	Provided MR
	C	Hose box	01	Provided MR
12	Yard Hydrants			
	A	Total no. of hydrants	NA	NA NA
	B	Hose box	NA	NA NA
13	Pumping arrangements Common with the Mall			
	A	Ground Level		
		a) Discharge of main pump	2280 LPM	Common with Mall MR
		b) Head of Main Pump	65 M	Common with Mall MR
		c) Number of Main Pump	02	Common with Mall MR
		d) Jockey Pump out put	180 LPM	Common with Mall MR
		e) Jockey Pump Head	65 M	Common with Mall MR
		f) Standby Pump out put	2850 LPM	Common with Mall MR
		g) Standby Pump Head	60 MH	Common with Mall MR
		h) Auto Starting/ Manual stopping	Required	Common with Mall MR
		i) Pump House access	Required	Common with Mall MR
	B	Terrace Level		
		Discharge of Pump	NA	NA NA
		Head of terrace pump	NA	NA NA
		Power supply	NA	NA NA
		Auto starting of pump	NA	NA NA
14	Captive Water Storage for Fire Fighting. Common with the Mall			
	A	Underground tank capacity	1,50,000 liters	Common with Mall MR
	B	Draw off connection	Required	Common with Mall MR
	C	Fire Service Inlet	Required	Common with Mall MR
	E	Access to tank	Required	Common with Mall MR
	D	Overhead tank capacity	10,000 litres	Common with Mall MR
15	Exit Signage		Required	Provided MR
16	Provision of lift			
	A	Pressurization of lift shaft	Required	Provided by mall MR
	B	Pressurization of lift lobby	Required	Provided by mall MR
	C	Communication in lift car	Required	Provided by mall MR
	D	Fireman switch	Required	Provided by mall MR
	E	Lift signage	Required	Provided by mall MR
17	Standby Power Supply		Required	Provided MR

18	Refuge Area			
A	location	N/A	N/A	N/A
B	Total area	N/A	N/A	N/A
19	Fire Control Room			
A	Fire Detection System panel	Required	Provided by mall	MR
B	Flow switch panel	Required	Provided by mall	MR
C	P A system panel	Required	Provided by mall	MR
D	Battery backup	Required	Provided by mall	MR
E	Building floor plan	Required	Provided by mall	MR
20	Special Fire Protection for special risk if any			
A	Special Fire Protection system for Protection of Special Risk, if any:	Required	Provided by mall	MR

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention & fire safety requirement under the rules and it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010.

Accordingly, DFA is prepared and placed opposite for perusal and approval please.

Note: - Last disposal date of the case is 14.06.2026.

Signature of the Inspecting Officer
Name: Mohd. Firoz Khan
Designation: ADO/Moti Nagar

D.O/WB

CFD/WB

Pr. Director

Limp
03/06/26

CFD to J.S.M.

CFD (WZ)
04/06/26
F.T. please.

Limp
06/06/26

ADO(MN)

Sts fit is put up for your kind perusal and signature please.

CFD/WB
08/06/26

F.P. wing
08/06/26