



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/2025/575

Dated: 11/04/2025

To

The Joint Commissioner of Police,
Licensing Unit, 1st Floor Defence Colony Police Station,
New Delhi.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s. Punjabi Bagh Club Restaurant located at Ground Floor, Punjabi Bagh Club, Delhi.

Sir,

This is in reference to the online application received through MHA portal vide ID- 2025031303468 on the subject cited above. In this regard, it is to inform you that the aforesaid building is comprised of basement, ground plus two upper floors, was issued fire safety certificate / NOC vide letter No. F.6/DFS/MS/GH/09/358 dated 05.02.2009 and renewal of the building is pending.

In view of above, the application for issuance of Fire Safety Certificate of restaurant cannot be considered at this stage & rejected. The owner/occupier/management of the Punjabi Bagh Club building may be directed to apply for renewal of the building in Form 'J' (Sub Rule 1 of Rule 37) alongwith a declaration in Form 'K', that after issuance of FSC for the entire building, renewal of FSC of the restaurant will be considered.

Yours faithfully

(VIRENDRA SINGH)

Chief Fire Officer
for Director
Delhi Fire Service

Copy to: -

1. The Manager, M/s. Punjabi Bagh Club Restaurant, Ground Floor, Punjabi Bagh Club, Delhi.
2. The Deputy Health Officer, MCD, West Zone, Vishal Enclave, Rajouri Garden, New Delhi- 27. (dhowestzone@gmail.com).

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI 10001

No. **F6/DFS/MS/GH/09/358**

Dated: **5-2-09**

To

The Deputy Health Officer (WZ)
M.C.D., Health Department
Delhi 110085

Subject: NOC from fire safety point of view in r/o Punjabi Bagh Club located at Punjabi Bagh, Ringh Road, New Delhi-26

Sir

In-continuation of this office letter No. D 685/ HD/ WZ/ 2008 dated 31.05.2008 to you and subsequent party letter No. nil dated 28.01.2009 on the above cited subject. The premises was inspected by the officers of this department with a view to ensure compliance of fire safety recommendations as communicated vide this office letter no. F.6/ DFS/ MS/ 2006/ 347 dated 08.02.2006. It observed that the club is comprised of basement, ground floor and two upper floors. The building contains guest rooms, library, gymnasium, indoor games court, swimming pool and open lawn etc. During the course of inspection, it was observed that the management has provided the requisite fire safety arrangements such as access to the building (rear entry gate), fire pumps, water static tank, wet riser system with fire hose box, first aid hose reel, automatic sprinkler system in the basement, fire extinguishers, automatic fire/ smoke detection system, manual call points, emergency light, exit signs, concealed electric wiring, MCB, smoke ventilation system in the basement and emergency power supply. The fire fighting systems were found functional during the inspection.

In view of the above, this department has no objection for grant of NOC from fire safety point of view subject to the following conditions:

1. All fire safety equipment be kept in good repairs at all time.
2. The employees and management shall know the correct operation of fire safety equipments.
3. No addition/ alteration be done without the approval of competent authority.
4. The management of the club shall be responsible for any loss of life or property due to non-operational of fire safety system or evacuation facilities in the building. The NOC from fire safety angle automatically stands cancelled in such circumstances.
5. The building department may verify the construction of the building in accordance with the norms of existing building byelaws.

Yours faithfully

**DY CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

Copy to:

1. The Executive Engineer (Bldg), M.C.D., Town Hall, Delhi 110006
2. The Supdt. (Club), Govt. of NCT of Delhi, Office of the Commissioner of Excise, Entt. And L. Tax Department, L & N Block, I P Estate, New Delhi
3. The Hony. General Secretary, Punjabi Bagh Club located at Punjabi Bagh, Ringh Road, New Delhi-26