

9/78

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/MN/Metro/2025/418

Dated: 08/08/2025

FIRE SAFETY CERTIFICATE

Certified that the Punjabi Bagh West Metro Station Halt Station on Green Line Punjabi Bagh West Metro Station Line No. 05, located at Punjabi Bagh, New Delhi-110026, comprised of Platform level & Interchange passage level (F.O.B.), was issued FSC vide Letter No. F6/DFS/MS/WZ/Metro/2022/379 dated 02/09/2022. The premises was re-inspected by the officer concerned of this department on 25/07/2025 in the presence of Sh. Puskar Singh (A.M Firer) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" (Group-D) sub Division D- with effect from 08/08/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 08/08/2025 at New Delhi by.


Virendra Singh
Chief Fire Officer

Copy to: -

1. Sh. Vivek Srivastava (JGM/E&M), Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations/ Addition & Alteration w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per UBBL.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1.	Name & address of the building	Punjabi Bagh West Metro Station Halt Station on Green Line Punjabi Bagh West Metro Station Line No. 05, located at Punjabi Bagh, New Delhi-110026.
2.	Type of Occupancy	Assembly (Platform Level & Interchange Passage Mezzanine/FOB)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/WZ/Metro/2022/379 dated 02/09/2022
5.	Fire Safety directives letter No	F6/DFS/MS/BP/2022/651 dated 21/03/2022
6.	Date of inspection	25/07/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sh. Puskar Singh (A.M Firer)
9.	Year of Construction	2010 (As per previous Inspection Report dated 22/08/2022)
10.	Applicant's letter No.	Letter No. DMRC/ODM/Fire/NOC/L-3/2025/15 dated 07/07/2025

The said building comprised of Platform level & Interchange passage level (F.O.B.).

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 mts	Provided	MR
	• Gate width	05 mts	Provided	MR
	• Width of internal road	NA	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	04	Provided	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1 x 1.8 m (PF to ML) 1 x 1.8 m (ML to GD) 2 x 4.2 m (PF to FOB)	Provided	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	02 mts	Provided	MR
	f. Width of Corridor	02 mts	Provided	MR
	g. Door Size			
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	@ 1 for 300 m ² , CO2 & WCO2	Provided	MR
	• Types	Required	Provided	MR
	• IS marking		Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	2 (at each PF)	Provided	MR
	• Length of hose reel hose	45 mts	Provided	MR
	• Nozzle diameter	25 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	02	Provided	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements. Provided at Punjabi Bagh West Elevated Metro Station Line 07			
	• Ground Level			
	➤ Discharge of main Pump	2850 lpm	Provided	MR
	➤ Head of Main pump	70m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	280 lpm	Provided	MR
	➤ Jockey pump head	70m	Provided	MR
	➤ Standby Pump out put	2850lpm	Provided	MR
	➤ Standby Pump Head	70m	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting. Connected with Existing Metro (Elevated) Line 07			
	• Underground tank capacity	100000 ltrs	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

Provision of Lifts.		NA	NA	NA
•	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	Required	Provided	MR
	Fireman's Grounding Switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NOVEC 1230 Flooding for ASS, HT,LT Pannel	Provided	MR

Note:- Abbreviation: - PF = Platform, ML = Mid Landing, GD = Ground Floor, FOB = Foot Over Bridge.

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/WZ/Metro/2022/379 dated 02/09/2022, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

Principal Director

CFO to Ssm.

Ado(mn)

CFO/Sup
5/8/2025

P. T. O