



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2026/WZ/EH/ 372

Dated: 20/04/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Punjabi Zaika, located at Shop No-3539-A, Ground Floor, Raja Park Shakur Basti, Delhi-110034, in the building comprised of ground + 03 upper floors and M/s Punjabi Zaika restaurant is running at ground floor only has already been issued FSC by this department vide letter No. F.6/DFS/MS/2023/EH/WZ/289 dated 21.09.2023. The premises was re-inspected by the officer concerned of this department on 11.04.2026 in the presence of Mr. Kulbahadur (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Assembly (Restaurant)" Group D for ground floor only with effect from 20/04/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/04/2026 at New Delhi by


(S. K. Dua)

Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic centre, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any: Online MCD Portal ID-2026032503540 dated 25.03.2026.
2. The Authorized Signatory, M/s Punjabi Zaika, located at Shop No-3539-A, Ground Floor, Raja Park Shakur Basti, Delhi-110034.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

N/29

INSPECTION REPORT

1. Name & address of the building	M/s Punjabi Zaika, located at Shop No-3539-A, Ground Floor, Raja Park Shakur Basti, Delhi-110034.			
2. Type of Occupancy	Assembly (Restaurant)			
3. Comprised of building	Ground + 03 upper floors			
4. Type of Case	Renewal (Punjabi Zaika restaurant is running at Shop No-3539-A, Ground floor)			
5. Details of Previous NOC	F.6/DFS/MS/2023/EH/WZ/289 dated 21.09.2023.			
6. Fire Safety directives letter No	-NA-			
7. Date of inspection	11.04.2026			
8. Name of Inspecting Officer	Ajay Kumar Sharma ADO (Wazirpur)			
9. Name and designation of officers From the building side	Mr. Kulbahadur (Manager)			
10. Year of Construction	2005 on MCD Portal			
11. Applicant's letter No.	Online application No.2026032503540 dated 25.03.2026.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6) of DFS Rules 2010.	Provided at site	Remarks MR/NMR
1.	Access to building		Provided	MR
	• Road width	06m		NA
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	Ground Floor	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	NA	Ground Floor	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	Provided	NA
	e. Width of Corridor	NR	NR	NR
	f. Door Size	02m, 01m	Provided	MR
3.	Compartmentation	NA	NA	NA
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	a) Basements	NA	NA	NA
	b) Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	a) Total numbers	05nos.	Provided	MR
	b) Types	ABC/CO2	Provided	MR
	c) IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	01nos.	Provided	MR
	b) Length of hose reel hose	30m	Provided	MR

64

	c) Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	NA	NA	NA
	b) Location of Main Panel	NA	NA	NA
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	NA	NA	NA
	e) Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	a) Basement	NA	NA	NA
	b) Ground & Upper Floors	NA	Provided	NA
	c) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	a) Size of riser/down-comer	100mm	Provided	MR
	b) Number of hydrants per floor	01nos.	Provided	MR
	c) Hose Box	01nos.	Provided	MR
12.	Yard Hydrants			
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA
	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA

N/31

18.	Refuge Area.			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	Fire Control Room			
	a) Detector System Panel	NA	NA	NA
	b) Flow Switch Panel	NA	NA	NA
	c) PA System Panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. **F.6/DFS/MS/2023/EH/WZ/289** dated **21.09.2023** is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer

[Signature]
11/11/25

Name: - Ajay Kumar Sharma
Designation:- ADO (Wazirpur)

~~20/10/23~~ 11/13/14

~~CFR~~ 15/04/26

~~Pr. Director~~

CFR to Room.

~~CFR (Cox)~~

[Signature]
17/04/26
F.T. please.

[Signature]
17/04/26

~~ADO (WOP)~~

FT letter is put up for kind perusal and signature please.

[Signature]
18/4/26

~~CFR~~

[Signature]
20/04/26

F.P. wing

Updated
20/4/26