



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2026/NZ/

728

Dated:

29/07/2026

To,

The Principal,
Pushp Jain Public School,
Kh. No. 867, Kadipur, Delhi-110036.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Pushp Jain Public School located at Kh. No. 867, Kadipur, Delhi-110036.

Sir,

This has reference to your letter no. PJPS/2026/102 dated 15/06/2026 received through outdoor diary no. 2346 dated 15.06.2026 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 13.07.2026 in presence of Sh. Vinod Kumar to see the compliance of requisite fire safety measures. During the course of inspection it is observed that school building is comprised of Two Blocks, Block 1- Ground floor and Block 2- Ground plus first floor. Your request for issuance of FSC is rejected due to the following shortcomings:

1. There is only one staircase of width 1.20 m provided against the requirement of two staircases having width 1.5 m each, both the staircases shall reach up to the terrace.
2. Class room door width found 1 m against the required width of 1.20 m.
3. First aid hose reel found not provided.
4. Terrace level pump of 450 lpm discharge capacity found not provided.
5. Overhead tank of 10,000 ltrs capacity found not provided.
6. Exit signage's not provided.
7. Building plan in a scale of 1:100 duly signed by registered architect and owner is not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, Delhi.