



e-34



FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/School/2025/NDZ/ 1214

Dated: 30/09/2025

FIRE SAFETY CERTIFICATE

Certified that the Puspanjali Modern Public School located at Main Road Tukmirpur Extn., Near Delhi Police Camp, Delhi -110090, comprised of Ground plus two upper floors (two separate blocks) owned/occupied by Puspanjali Modern Public School was issued FSC vide letter No. F.6/DFS/MS/2022/NDZ/943 dated 02/09/2022. The premises was re-inspected by the officer concerned of this department on 22/09/2025 in the presence Sh. Yogesh Vats, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" (Group-B) with effect from 30/09/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 & also conditions printed below.

Issued on... 30/09/2025 at New Delhi by.


(VIRENDRA SINGH)
CHIEF FIRE OFFICER

To,

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053
2. The Manager, Puspanjali Modern Public School located at Main Road Tukmirpur Extn., Near Delhi Police Camp, Delhi -110090

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/19

1. Name & address of the building : Puspanjali Modern Public School
Main Road Tukmirpur Extn., Near Delhi Police Camp, Delhi-110090
2. Building is comprised of : G+2 (Two separate blocks)
3. Type of Occupancy : Educational, Group-B
4. Type of Case : Addition/Alteration
5. Details of Previous NOC letter : F.6/DFS/MS/ 2022/NDZ/943 dt 02/09/2022
6. Fire Safety direction letter No. : NBC Part IV
7. Date of Inspection : 17/09/2025
8. Name of the Inspecting officers : ADO Deepak Kumar
9. Name and designation of Officer
from the building side : Sh. Yogesh Vats, Manager
10. Year of Construction : 2012 & 2013
11. Applicant's letter No : ppushpanjalschool@gmail.com dated 02/09/2025

| Sr. No. | Minimum Standards on fire prevention and fire safety U/R33 | NBC Part IV/BBL Requirement | Provided at Site | Remarks MR/NMR |
|---------|--|--|---|----------------|
| 01 | Access to building | | | |
| | • Road width | 06 m | 06 m | MR |
| | • Gate width | N/A | N/A | N/A |
| | • Width of internal road | N/A | N/A | N/A |
| 02 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | | | |
| | • Upper Floor | 01 no. first block) 01 no. 2 nd block) | 01 no. (first block) & 01 no. (2 nd block) | MR |
| | • Basement | N/A | N/A | N/A |
| | B. Width of Staircases | 1.50 m + 1.50 m | 1.50 m (first block) & 1.50 m . (2 nd block). | MR |
| | • Upper Floor | N/A | N/A | N/A |
| | • Basement | N/A | N/A | N/A |
| | c. Protection of exits | N/A | N/A | N/A |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | | | |
| | d. No. of continuous staircases to terrace | 01 nos. in each block | 01 nos. in each block | MR |
| | e. Width of Corridor | 1.50 m | 1.60 m & 1.55 | MR |
| | f. Door Size | 01 m | 01 m | MR |
| 03 | Compartmentation. | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire rating of shaft door | N/A | N/A | N/A |
| | • Water curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 04 | Smoke Management System. | | | |
| | • Basement | 12 ACPH | Provided | MR |
| | • Upper floor | N/A | N/A | N/A |

N/20

| | | | | |
|-----|---|----------------------|----------------------|-----|
| 05. | Fire Extinguishers | | | |
| | • Total numbers | 12 nos. | 16 nos. | MR |
| | • Types | ABC /CO ₂ | ABC /CO ₂ | MR |
| | • IS marking | ISI marked | ISI marked | MR |
| 06 | First-aid-Hose Reels. | | | |
| | Total numbers on each floor | 01 no +01 no. | Provided | MR |
| | • Length of hose reel hose | 30 mtr | Provided | MR |
| | • Nozzle diameter | 05 mm | Provided | MR |
| 07 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of main panel | N/A | N/A | N/A |
| | • Location of repeater panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooter's location | N/A | N/A | N/A |
| 08 | MOEFA | N/A | N/A | N/A |
| 09 | Public address System. | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • upper floor | N/A | N/A | N/A |
| | • sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | • size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | N/A | N/A | N/A |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main Pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby pump out put | N/A | N/A | N/A |
| | ➤ Standby pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting /Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | | | |
| | • Terrace Level | | | |
| | ➤ Discharge of pump | 450 lpm | 450 lpm | MR |
| | ➤ Head of the Pump | 40 mtr | 40 mtr | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto Starting of pump | Required | Provided | MR |

| | | | | |
|----|--|------------|------------|-----|
| 14 | Captive Water Storage for Fire Fighting. | N/A | N/A | N/A |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw-off connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | Required | Provided | MR |
| | • Overhead Tank capacity | 10,000 ltr | 10,000 ltr | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | | | |
| 18 | Refuge Area. | | | |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | | | |

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No. F.6/DFS/MS/ 2022/NDZ/943 dt 02/09/2022 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is **recommended**.

Deepak 23/09/2025
 Signature of the Inspecting Officer
 Name :- Deepak Kumar
 Designation :- A.D.O (Shahdara)

DO (ED) *Deepak* 23/09/2025
 Dy C.F.O. (NDZ) *Deepak* 24/09/25

C.F.O. *Deepak* 25/09/2025
 Principal Director

A.D.O (Shahdara)

Deepak 25/09/25