

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2025/ *EH/379*

Dated: *22*/09/2025

To,

The Manager,  
M/S QDS ( Food World Hospitality Pvt. Ltd.) ,  
1st & 2nd floor Qtr no. 1A, Block 1,  
Lajpat Nagar-II, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S QDS ( Food World Hospitality Pvt. Ltd.) located at 1st & 2nd floor Qtr no. 1A, Block 1, Lajpat Nagar-II, New Delhi.

Sir,

This has reference to ID No. 2025082312799 dated 27.08.25, on the subject cited above, it is to inform you that the site was inspected by the officer concerned of this department on 10/09/2025 in the presence of Manager and the following shortcomings were observed:-

1. Alternate exit found blocked required to be cleared all time for freely evacuation of occupants.
2. Overhead tank is provided of 10,000 liter capacity against the requirements of 20,000 liter.

In view of above, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully

*[Signature]*  
*22/9/2025*  
(Virendra Singh)  
Chief Fire Officer

Copy to:-

The Commissioner MCD, Civic Centre, New Delhi.